

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7320-1591:168 Page 1 of 1

CATEGORY: Speakers

LISTEE: Edwards Systems Technology, 6411 Parkland Drive, Sarasota, FL 34243
Contact: Leon Newsome (941) 739-4276 Fax (941) 739-4334

DESIGN: Speaker/Strobes. Models listed below:

765-5A, 765-7A, 765-8A
767-5A, 767-7A, 767-8A
964-3A-4R, 964-3A-4S, 964-3A-8R, 964-3A-8S
964-5A-4R, 964-5A-4S, 964-5A-8R, 964-5A-8S
964-7A-4R, 964-7A-4S, 964-7A-8R, 964-7A-8S
964-8A-4R, 964-8A-4S, 964-8A-8R, 964-8A-8S
965-3A-4R, 965-3A-4S, 965-3A-8R, 965-3A-8S
965-5A-4R, 965-5A-4S, 965-5A-8R, 965-5A-8S
965-7A-4R, 965-7A-4S, 965-7A-8R, 965-7A-8S
965-8A-4R, 965-8A-4S, 965-8A-8R, 965-8A-8S

First suffix may be any alphanumeric character. May be followed by "W" or "R" to designate color. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as speakers for use with separately listed compatible control unit. Speakers are provided with a strobe for the hearing impaired. For indoor use only. Speakers may be round or square in design.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

NOTE: Formerly 7135-1388:187, 7320-1388:187

11-02-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager